

This drawing is the copyright of Axiom Architects. The contractor is to check all site dimensions and levels before work starts. This drawing must be read with and checked against all structural and other specialist drawings, specification and bills of quantities. Notify architect of any discrepancies. The contractor is to comply with all current British Standards and Building Regulations whether or not specifically stated on these drawings. Do not scale from drawings.

Licensable activities occur within the red line  
Loose furniture is indicative only



EXIT  
MAX NO. OCCUPANTS 46  
MIN. CLEAR OPENING 750mm

EXIT  
MAX NO. OCCUPANTS 42  
MIN. CLEAR OPENING 750mm

**FIRE RATING:**  
 --- 30 Minute fire resistance to walls  
 --- 60 Minute fire resistance to walls

**FIRE ESCAPE ZONES:**  
 Horizontal fire escape zone  
 Vertical fire escape zone  
 Services zone

Note: Service access points / panels - Subject to confirmation from Mechanical & Electrical design consultant.

Fire alarm designed to BS 5839-1: 2013  
 Emergency lighting designed to BS 5266-1: 2011  
 Escape signage designed to BS 5499

F 6 ltr AFFF Foam Extinguisher  
 co2 2kg co2 extinguisher

Rev	Date	Description	By
A	31/03/20	Fire Extinguisher locations added.	AJB

**AXIOM ARCHITECTS**  
 1st Floor Arlington House, Park Five Business Center Exeter EX2 7HU  
 Tel. 01392 368426 www.axiomarchitects.co.uk

Client  
**CARTER LAUREN CONSTRUCTION LTD**

Project  
 MOLLIES MOTEL & DINER  
 CRIBBS CAUSEWAY,  
 BRISTOL

Drawing  
**FIRE STRATEGY - SECOND FLOOR**

Scale	Status	Date	Drawn	Checked
1:100 @A1	CONSTRUCTION	29/01/20	AJB	

Drawing No. **5146/212** Revision **A**